

4
a

APPENDIX - XIII

SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE

NO. CBT/HS/1365

Date: 09/10/26

It is certified that an inspection team headed by
A. S. PARIHAR, SANITARY INSPECTOR (Name of Officers with
designation) from Office of the Chief Executive Officer, Cantonment Board, Jabalpur
(Name of Department/Office) inspected the "ST. ALOYSIUS SENIOR SECONDARY
SCHOOL, 1, Shakti Marg, Cantt., Jabalpur District (MP)" on 01/10/2026 and found
that the "ST. ALOYSIUS SENIOR SECONDARY SCHOOL, 1, Shakti Marg, Cantt., Jabalpur
District (MP)" has safe drinking water facilities for the students and members of staff
of the institution and is maintaining the hygienic sanitation condition in the school
building and the campus as per the norms prescribed by the Central/State/Union
Territory Government.

The above valid for a period of 01 Year

Signature with Seal : PTS

Name : RAJEEV KUMAR

Designation : CHIEF EXECUTIVE OFFICER

To,

The Principal
St. Aloysius Senior Secondary School
1, Shakti Marg, Cantt.
Jabalpur

Chief Executive Officer
Cantonment Board,
Jabalpur

DISTRICT WATER TESTING LABORATORY
Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.

WATER TESTING REPORT

Report No. <u>67</u>	Date <u>2/9/2026</u>	UID No. JBP/
Ref. NO. <u>SASSS/F-09/</u>	Date <u>31/8/2026</u>	Village & Location
To, <u>Principal</u> <u>St. Aloysius Senior Secondary</u> <u>School Contt. Jabalpur.</u>		1- <u>St. Aloysius Senior Secondary</u> <u>School Contt. Jabalpur.</u> <u>Water Source- water cooler.</u>
Sample Collected by <u>School Staff</u>	Date of collection <u>31/8/2026</u>	2-
Source <u>Water Cooler.</u>	Date of receipt <u>31/8/2026</u>	3-
Date of Testing <u>31/8/2026</u>		
Test conducted by <u>Kavita, Vithika</u>		

As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	TEST RESULT	
					1	2

PHYSICAL-TEST

1	Turbidity	NTU	1.0	5.0	<u>1.2</u>	
2	Colour	Pt. Cobalt	1.0	25.0	<u>-</u>	
3	Taste & Odour	Agreeable	Agreeable	Agreeable	<u>Agreeable</u>	

CHEMICAL-TEST

4	pH	...	6.5 to 8.5	6.5 to 8.5	<u>7.72</u>	
5	Conductivity	M. Mohs/cm	..	..	<u>794</u>	
6	Alkalinity	mg/l	200	600	<u>250</u>	
7	Chloride (As Cl)	mg/l	250	1000	<u>55</u>	
8	Nitrates	mg/l	45	45	<u>2.0</u>	
9	Total Hardness (As CaCO ₃)	mg/l	200	600	<u>470</u>	
10	Calcium (As Ca)	mg/l	75	200	<u>92</u>	
11	Magnesium (As Mg)	mg/l	30	100	<u>58.44</u>	
12	Total dissolved solid	mg/l	500	2000	<u>576</u>	
13	Iron (As Fe)	mg/l	1.00	1.0	<u>0.2</u>	
14	Manganese (As Mn)	mg/l	0.10	0.30	<u>0.0</u>	
15	Fluoride (As F)	mg/l	1.00	1.50	<u>1.1</u>	
16	Sulphates As So ₄	mg/l	200	400	<u>0.38</u>	
17	Residual Chlorine	mg/l	0.20	1.0	<u>-</u>	

BACTERIOLOGICAL-TEST

18	Total Coliform	per 100ml	0	..	<u>0</u>	
19	E Coli or Thermo tolerant coliforms	per 100ml	0	..	<u>0</u>	

Remark:-

Note:- 1. As above result compared with BIS 10500:2012

2. Samples are not collected by us.

3. Not to be produced at court of law.

4. We do not take any responsibility for deviation in test result due to wrong collection of sample

Kavita Rajak
02/9/2026
Chemist
District Laboratory
Jabalpur